



Selma Fire Department  
Fire Prevention Bureau  
9375 Corporate Dr.  
Selma, TX 78154  
210.651.7832



## Fire Lane Specifications

- Fire Lanes will be determined by the Selma Fire Department and/or owner/lessee of the subject
- Fire Lanes shall be marked by painted red lines that is six (6") in width
- All curbs shall be stenciled "NO PARKING FIRE LANE" or "FIRE LANE NO PARKING"
- Lettering shall be four (4") inches in height and white in color at 25' intervals
- Fire lane width no less than 26'



### FIRE LANE SIGN SPECIFICATIONS (when approved by the fire code official)

- Sign dimensions shall be 12" wide and 18" high
- White background with red letters and red border
- Signs shall read "NO PARKING FIRE LANE" or "FIRE LANE NO PARKING"
- Lettering shall not be less than two (2") inches in height
- Signs shall be permanently affixed to a stationary post 6'6" above the finished grade
- Signs shall not be placed more than 50' apart



**\*\*Guidelines may be modified with approval from the Selma Fire Prevention Bureau\*\***